



**NOTES:**

- (A) ROMAC AND MUELLER DOUBLE STRAP SERVICE SADDLES WITH C.C. THREAD TO BE USED ON ALL MAINS.
- (B) CORPORATION STOPS: 1 1/2" & 2" - FORD BALLCORP CORPORATION STOP #FB400 OR #FB500 (EQUAL MUELLER OR A.Y. MCDONALD BRASS MAY BE SUBSTITUTED).
- (C) BRASS PACK JOINT AND BRASS OR COPPER COMPRESSION FITTING WITH 45° OR 22.5° BEND AS REQUIRED.
- (D) COPPER TUBING TYPE K (SOFT), 4 INCHES OF SAND BEDDING ALL AROUND PIPE, CONTINUOUS UNBROKEN LENGTH FROM MAIN TO METER SETTER WITH 1 FOOT OF SLACK LOOP.
- (E) METER SETTERS: 1 1/2" - FORD #VBH86-12B-11-66  
2" - FORD #VBH87-12B-11-77  
VERTICAL IN - VERTICAL OUT WITH BYPASS.
- (F) METERS SHALL BE INSTALLED BY THE CITY WATER DIVISION AT OWNER'S EXPENSE.
- (G) METER BOXES SHALL BE SIGMA RMB 111812-SW-W WITH "CITY OF LYNNWOOD PUBLIC WORKS" SHOWN ON COVER OR APPROVED EQUAL. METER BOX LOCATION SHALL BE THE FIRST AVAILABLE OF THE FOLLOWING LOCATIONS:
  1. BEHIND SIDEWALK
  2. AS CLOSE AS POSSIBLE TO THE BACK OF SIDEWALK, WITH SLIP RESISTANT LIDS PER PROWAG R302.7.
- (H) COPPER TYPE K (SOFT), PEX OR POLYETHYLENE LINE; A COPPER TRACER WIRE IS REQUIRED FOR NON-METALLIC PIPE. 4 INCHES OF SAND BEDDING ALL AROUND PIPE. PRIVATE LINE INSTALLATION SHALL COMPLY WITH 7-15.3 OF THE CURRENT WSDOT SPECIFICATIONS.

DRAWING NUMBER	U-WAT-2
SCALE	NONE
REVISION DATE	10/21
DEPARTMENT	PW